

knowledge

Honeywell




2015 Honeywell Users Group Americas
Forty Years of Innovation.

Why not in my DCS?

Critical safety safeguards in a DCS are not a good idea
Leoncio Esteves-Reyes, Performance Materials Technologies

Introduction

- If I have this




- Why do I need that?





This is your DCS' mission

- Drives plant operations within normal range
- Always acting: sensing and intervening
- Generates actions and alarms
- Informs, so operators can act



Can the DCS act like an SIS?

- With the right coding, will this...



...become that?



IEC 61508 written to help design and develop SIL rated products for any industry.

IEC 61511 and ISA84.00.01 (almost identical) written to help analyze, design, implement, install, commission and maintain SIL loops for the Process industry.

An SIS:

- **Implements SIF(s) to keep the process safe**
- **The SIF(s) are defined by their SIL**
 - **Success rate at keeping process safe state**
 - **Four levels of probability**
- **Is composed of three elements**
 - **Sensors, Logic Solvers and Actuating Devices**

What about the SIL?

SIL:

- **Four levels used to specify SIS requirements**
- **Based on probabilities of success over time**

SIL Levels:

- **1 → Lowest**
- **4 → Highest**

Standards say this is SIS' mission

- **Brings process back from the brink and takes the process to a safe state**
- **Acts infrequently and sparingly**
- **Only informs after taking corrective action**



Let's compare BPCS and SIS

Hardware:

- Redundancy
- Failure
- SIL

Software:

- Programming language
- Firmware
- Diagnostics
- Application complexity


Functionality:

- Main use
- Demand
- Place as protection layer
- Controller interactions
- Response time

Operator Intervention:


- **Management of Change (MOC)**
- **Operator mistakes**
- **Logic changes**
- **Handling by-passes**

An application from industry



BPCS credits

- So why is BPCS given ONLY ONE credit in ISA 84.00.01 ?
- Why can't I take additional credit if I have a configuration as below for PIC-101 and PSH-102 ?




For BPCS, let's see what happens if...

Operator Intervention:

- Puts 101 in manual and, after a few days...
- PSH-102 is by-passed

Application Software:

- New “Go To” loop applied before PSH-102 logic...
- Never validated (not required)




For BPCS, let's see what happens if... (II)

Firmware:

- DCS OS is upgraded and...
- Bug affects all PID controllers


Third Party Interface:

- A local PLC sends a garbled message to DCS...
- Local logic is affected



SIS credits


- PIC-101 is part of BPCS
- PSH-102 is part of SIS



Let's see what happens if...

Operator Intervention:

- Puts 101 in manual and, after a few days...
 - PSH-102 in SIS is bypassed
- PIC-101 is part of BPCS
 - PSH-102 is part of SIS



Application Software:

- New “Go To” loop applied before PSH-102 logic in SIS


Let's see what happens if... (II)

Firmware:

- DCS OS is upgraded and SIS OS upgraded...
- Bug affects all PID controllers
- PIC-101 is part of BPCS
- PSH-102 is part of SIS

Third Party Interface:

- A local PLC sends a garbled message to DCS...
- Local logic is affected



Need to add or modify DCS

- Add diagnostics
- Modify firmware
- Forbid operator changes
- Forbid exchanges with other controllers

In other words:

Redesign the DCS to make it behave as an SIS

Why bother if we already have designed SIS'?

BPCS and SIS have distinct and specific roles

Let's leave each do its job

**The standard is clear about the
characterization of a BPCS, as a system**

**“...which does not perform any safety
instrumented functions with a claimed SIL \geq
1”**

Honeywell